

SECTION 6

6.15 SIZE OF METER:

Meters shall be of the same size as the corporation stop and that portion of the service pipe between the meter and the corporation stop. In no case shall a meter smaller than 3/4 inch be installed, except as a replacement for an existing smaller meter.

Denver Water may allow the installation of a meter of a size smaller than the service pipe in cases where the full capacity of a previously used service pipe is not required provided that the service pipe is reduced to the size of the meter for a distance of not less than 10 times the larger pipe diameter on the inlet (supply) side of the meter.